



Briefing: Vaccines, Variants, and Ventilation

A Briefing on Recent Scientific Literature Focused on SARS-CoV-2 Vaccines and Variants, Plus the Effects of Ventilation on Virus Spread

Dates of Search: 01 January 2021 through 26 April 2021

Published: 20 May 2021







INTRODUCTION









Purpose of This Briefing

- Access to the latest scientific research is critical as libraries, archives, and museums (LAMs) work to sustain modified operations during the continuing severe acute respiratory syndrome coronavirus 2 (SARS-CoV-2) pandemic.
- As an emerging event, the SARS-CoV-2 pandemic continually presents new challenges
 and scientific questions. At present, SARS-CoV-2 vaccines and variants in the US are
 two critical areas of focus. The effects of ventilation-based interventions on the
 spread of SARS-CoV-2 are also an interest area for LAMs. This briefing provides key
 information and results from the latest scientific literature to help inform LAMs making
 decisions related to these topics.

How to Use This Briefing: This briefing is intended to provide timely information about SARS-CoV-2 vaccines, variants, and ventilation to LAMs and their stakeholders. Due to the evolving nature of scientific research on these topics, the information provided here is not intended to be comprehensive or final. As such, this briefing should be used in conjunction with other timely resources to ensure decision-making reflects the latest scientific understanding. Continual re-evaluation of SARS-CoV-2 policies is highly recommended as new scientific discoveries are published.









About This Briefing

- Battelle conducted a systematic search of scientific literature about SARS-CoV-2 vaccines, variants, and ventilation. This briefing summarizes those findings.
- Research questions:
 - 1. What implications does SARS-CoV-2 vaccination in the US have for public health interventions and policies, especially related to indoor environments?
 - 2. How do SARS-CoV-2 variants currently circulating in the US differ from the original strain in terms of spread, transmissibility, surface attenuation, and effectiveness of public health interventions?
 - 3. What effects do ventilation and ventilation-based interventions (e.g., heating, ventilation, and air conditioning systems (HVAC)) have on the spread of SARS-CoV-2 in indoor environments?
- Dates of search: 01 January 2021 to 26 April 2021
- Additional information about the methods used to conduct the literature search and create this briefing are included later in the document.









About REALM

REopening Archives, Libraries, and Museums (REALM) is a research project conducted by OCLC, the Institute of Museum and Library Services, and Battelle to produce and distribute science-based COVID-19 information that can aid local decision making regarding operations of archives, libraries, and museums.

View reports published by REALM.









BACKGROUND INFORMATION: VACCINES AND VARIANTS










SARS-CoV-2 Vaccines

- Vaccination efforts in the US are underway.
- The CDC reports updated vaccination numbers daily on a COVID-19 data tracker.¹
- Three safe and effective vaccines are distributed under the US FDA Emergency Use Authorization:²
 - Pfizer-BioNTech: 2-dose series, 21 days apart³
 - Moderna: 2-dose series, 28 days apart⁴
 - Janssen (Johnson & Johnson) (J&J): Single dose⁵
- CDC recommends getting the first vaccine available.³
- On April 23, 2021, CDC and FDA recommended use of the J&J vaccine after a brief pause in the US. Both agencies noted women 50 years of age and younger should be made aware of an increased risk of a rare adverse event that involves blood clots.⁶

Total Doses Administered Reported to the CDC by State/Territory per 100,000 of the Total Population (as of 18 May 2021)



**Vaccination rates by county are also available









SARS-CoV-2 Vaccines

- The CDC recommends that everyone age 12 or older get a COVID-19 vaccine.
- Vaccines are widely available now and the US government is working to make vaccines free and available to everyone.⁷
- CDC has indicated that people who are fully vaccinated can resume some activities they stopped due to the pandemic.
 CDC continues to review infection rates across the country and release guidance on precautions that both vaccinated and non-vaccinated people should take to stop the spread of COVID-19.8
 - Lists of what may and may not be safe to change are on the CDC website.

More information about finding local vaccination sites: ⁷

- Vaccines.gov
- Text a zip code to 438829
- Call 800-232-0233









Variants of SARS-CoV-2

What is a Variant?

- Viruses inherently replicate, which can result in genetic changes or mutations. After enough mutations occur, the new version is called a variant. As expected, multiple SARS-CoV-2 variants have been found in the US and abroad during this pandemic.
- Sometimes new variants emerge and disappear, and other times new variants emerge and persist.⁹

Types of Variants ¹⁰

- There are three types of variants. The types differ based on the possibility
 of the variant to affect people negatively, such as increased transmissibility.
 In order from least to most negative effects:
 - Variants of Interest (Vol)
 - Variants of Concern (VoC)
 - Variants of High Consequence (VoHC)
- As of this report, in the US there are eight Vol, five VoC, and zero VoHC.

REALMPROJECT





BATTELLE

Why is it important to track variants?

Monitoring variants can help find out:

- How the virus changes over time into new variants
- How these changes affect aspects of the virus
- How the changes might impact health. ¹¹

Variants of SARS-CoV-2

CDC Variants of Concern (VOC)

"A variant for which there is evidence of an increase in transmissibility, more severe disease (increased hospitalizations or deaths), significant reduction in neutralization by antibodies generated during previous infection or vaccination, reduced effectiveness of treatments or vaccines, or diagnostic detection failures." 10

Information about reported cases of variants by state is available from the CDC.

Current Variants of Concern in the US (as of 18 May 2021)

| Variant | First Detected | Other Names |
|---------|------------------------|-------------|
| B.1.1.7 | United Kingdom (UK) | 20I/501Y.V1 |
| P.1 | Japan/Brazil | 20J/501Y.V3 |
| B.1.351 | South Africa | 20H/501.V2 |
| B.1.427 | US – California | 20C/S:452R |
| B.1.429 | US – California | 20C/S:452R |









SUMMARY OF FINDINGS: SYSTEMATIC SEARCH OF SCIENTIFIC LITERATURE ABOUT SARS-COV-2 VACCINES, VARIANTS, AND VENTILATION

















Impact of Vaccines

- Long-term impacts of the vaccines are still being studied.
- After the first vaccine dose, viral loads appear to substantially decrease, which may mean a decrease in infectiousness, transmissibility, and disease burden. 12, 13
- Positive tests for COVID-19 after receiving both doses of vaccine (Moderna and Pfizer) are rare according to data from two California health care systems that studied healthcare workers' infection rates after vaccination. ¹⁴
 - Although absolute risk of testing positive for SARS-CoV-2 after vaccination was slightly higher than the risks reported in clinical trials, the healthcare workers' demographics were different than those in the clinical trials and healthcare workers were at higher risk of exposure.









Impact of Vaccines (Continued)

- Antibodies produced by the Moderna vaccine lasted for at least 119 days after the first vaccination.¹⁵
- A study on response to the Pfizer-BioNTech mRNA vaccine showed that after a single dose, persons who had a prior COVID-19 infection saw an antibody response that was similar to that of people without prior infection who received two doses.¹⁶
- Results of an agent-based COVID-19 transmission model indicated that vaccination can help prevent COVID-19 outbreaks.¹⁷









Vaccine Hesitancy and Vaccine Safety

- Vaccine safety is assessed during the development process and is still
 continuously monitored. ¹⁸⁻²³ While states have expanded vaccine eligibility,
 surveys continue to show "vaccine hesitancy" remains a concern for ensuring
 equitable vaccination coverage among all populations. ^{24, 25}
- Factors potentially related to vaccine hesitancy include: concerns over vaccine safety, trust in government recommendations, perceived political interference, education, income, race/ethnicity, and perceived threat of COVID-19. ²⁶⁻³⁴
- The CDC and FDA recommended a pause in administration of the J&J vaccine to allow for a safety review by CDC's Advisory Committee on Immunization Practices (ACIP). The pause was lifted 10 days later, and vaccinations resumed. 35
- Preliminary findings of vaccine safety (mRNA vaccines) for pregnant persons did not show any obvious safety signals to pregnancy or neonatal outcomes, but continued monitoring was recommended. 36









Health Communication and Miscommunication

- Scientists have called for efforts to address miscommunication and misinformation on COVID-19 vaccines and restore trust in health authorities.³⁷⁻³⁹
- Increasing vaccine acceptance will be impeded by vaccine misinformation and poor public health communication strategies.³⁹⁻⁴²
- Equitable access to COVID-19 vaccines among racial/ethnic minorities is a key concern. Researchers have identified that COVID-19 continues to disproportionally impact the Black community, further worsening health disparities already present due to racism and its effects on social and economic factors. ^{25, 43, 44}
- A rapid expert consultation from the National Academies of Sciences, Engineering and Medicine recommended emphasizing support for vaccines, leveraging endorsements, focusing on hesitant individuals, and engaging communities to increase confidence in the vaccine. 45









What is Still Unknown About SARS-CoV-2 Vaccines? 2,7

- How long immunity lasts for different vaccines.
- How well the vaccines keep people from spreading SARS-CoV-2 to others, even without symptoms.
- How and when vaccines will be available for children under 12 years old.
- How well different vaccines will protect against future SARS-CoV-2 variants.
- How dosing with two different vaccines for first and second doses can affect efficacy (e.g., Pfizer then Moderna).









Key CDC Resources About SARS-CoV-2 Vaccines

- CDC Vaccines for COVID-19 site
- COVID-19 Vaccination Toolkits (Community-Based Organizations)
- CDC Guidelines on How Fully Vaccinated People Can Visit Safely with Others
- Key Things to Know About COVID-19 Vaccines
- Facts about COVID-19 Vaccines:
 - English version
 - Spanish version
- COVID-19 Vaccinations in the United States

















Spread, Transmissibility, and Infectivity

- Several studies suggested that emerging SARS-CoV-2 variants, specifically the B.1.1.7 (first detected in the UK) and B.1.351 variants (first detected in South Africa), are more transmissible than the early lineage variant.⁴⁶⁻⁵²
 - One study found that in the US, the B.1.1.7 variant is ~50% more transmissible than other circulating variants, has a growth rate of ~7.5% per day, and has a doubling rate of 1.5 weeks. ⁵³
 - Another study found that the B.1.1.7 variant has an estimated 43-90% higher reproduction number than preexisting variants in England, 45–66% higher than those in Denmark, and 56-63% higher than those in the US.⁵⁴
 - A study in France showed that from 25 January to 16 February 2021, SARS-CoV-2 infections from variants (B.1.1.7, B.351, and P.1) were associated with more rapid spread of SARS-CoV-2 infections than anticipated, such that by February 16, more than half of infections in the country were caused by variants. ⁵⁵









Spread, Transmissibility, and Infectivity (Cont.)

- Certain mutations in the B.1.1.7 and B.1.351 variants and SARS-CoV-2 substrains have been found to be linked with increased transmissibility and infectivity. 56-60
- Findings have shown that the higher infectivity and rapid spread of the B.1.1.7 variant may be linked to the higher viral load found in samples from people with the variant. 61
- A study of the spread of COVID-19 in the US by county found that regions with high proportions of two SARS-CoV-2 variants with a specific mutation (the G614 mutation) had higher spread rates than regions with lower proportions of those variants. 62
- A study found the stability of the B.1.1.7 variant in aerosols in different environmental conditions (varying temperature, relative humidity, and simulated sunlight) was similar to other previously identified variants, suggesting that the increased transmissibility of B.1.1.7 is not due to an enhanced ability to survive in the environment. 63









Outcomes Severity for Variants (compared to original version of SARS-CoV-2)

- Studies have found that the B.1.1.7 variant is associated with increased mortality in England compared to pre-existing variants. ^{64, 65}
- A study found that SARS-CoV-2 persisted longer in people infected with the B.1.1.7 variant (16 days) compared to those infected with other variants (14 days).
- Research suggests that specific mutations that have been identified in SARS-CoV-2 variants are associated with varying severity of COVID-19 illness.
 - One study identified five mutations of the virus that were associated with mild outcomes and 17 mutations that were associated with severe outcomes.⁶⁷
 - One study indicated that a common mutation found in all currently identified VoCs (the D614G mutation) is not associated with more severe disease outcomes.⁶⁸
 - Two mutations identified in SARS-CoV-2 variants were found to have opposing outcomes.
 One mutation (in gene N [P13L]) was associated with decreased deaths and decreased cases per million, whereas another mutation (in gene ORF3a [Q57H]) was linked to decreased deaths and increased cases per million. ⁶⁹
- Findings from a study examining global data showed a potential link between a variant with the S-D614G mutation and increased case severity.









Risk of Reinfection

- Case reports highlight instances of reinfection with the B.1.1.7 SARS-CoV-2 variant following previous infection with the early lineage virus. 71-73
- One study reported that the B.1.351 variant has an "unusually large number of mutations," some of which might be linked to immunoescape (i.e., the virus escapes being stopped by the immune system). Thus, it is unclear whether infection for one SARS-CoV-2 strain offers protection against reinfection by another strain.
- A study found that the B.1.1.7 and B.1.351 variants are more resistant to neutralization (i.e., they are less likely to lose infectivity), which suggests there was evidence of the possibility of reinfection with these strains. ⁷⁵
- Despite there being a possibility of reinfection with VoCs, one study showed no evidence of increased reinfection rates in the presence of the B.1.1.7 variant. ⁵¹









Impact of Therapies and Vaccines on the Variants

- A study showed that plitidepsin and ralimetinib, two host-directed drugs used in the treatment of SARS-CoV-2, as well has remdesivir have antiviral effects against both the early lineage and the B.1.1.7 variant of SARS-CoV-2. 76
- Vaccine BNT162b2 (Pfizer-BioNTech) appears to be highly effective against the B.1.1.7, B.1.351, and P.1 lineage variants of SARS-CoV-2 77 and the D614G mutation. 56, 78
- The Moderna mRNA-1273 vaccine has been shown to maintain neutralizing activity against all circulating SARS-CoV-2 variants except the B.1.351 variant, which has shown some resistance to the vaccine. 79-81
- Findings indicated that a single dose of the Pfizer-BioNTech or Moderna vaccines may increase neutralizing activity against the B.1.1.7, B.1.351, and P.1 variants for individuals who were previously infected with SAR-CoV-2. 82, 83









Continued Use of Established Mitigation Strategies

- Studies show that it is critical to continue existing public health strategies (e.g., physical distancing, hand hygiene, mask wearing, people quarantining after exposure) to reduce the transmission of SARS-CoV-2 variants while vaccine coverage expands. 84-86
- A study using an epidemiological model showed that accounting for variants, reinfection, and optimal control – relaxing mitigation measures early would lead to a sharp increase in new cases.⁸⁷
- A model examining the impact of social distancing measures in France on the spread of SARS-CoV-2 showed that although these measures reduced the effective transmission rate of previously circulating SARS-CoV-2 strains, they did not lead to a decline in the spread of the B.1.1.7 variant due to the variant's more efficient transmission.⁸⁸
 - These findings suggest that maintaining rigorous mitigation strategies alongside increased vaccination may be the most effective way to minimize the spread of the B.1.1.7 variant.
- A study of the spread of the B.1.1.7 variant in Portugal over a six-week period showed a deceleration in the growth rate of the variant after physical distancing measures were put in place. 89









What is Still Unknown About SARS-CoV-2 Variants? 2,9

- How transmissible some variants of SARS-CoV-2 are for certain demographics (e.g., older adults).
- The likelihood of reinfection due to SARS-CoV-2 variants.
- How the infectious dose (amount of virus needed for infection) differs between variants and the early lineage.
- How these variants may affect existing therapies, such as vaccines.
- How widely variants have spread in the US and abroad.









Key CDC Resources About SARS-CoV-2 Variants

- Variants of the Virus that Causes COVID-19
- About Variants of the Virus that Causes COVID-19
- Science Brief: Emerging SARS-CoV-2 Variants
- US COVID-19 Cases Caused by Variants

















General Findings

- Many of the studies used carbon dioxide as a proxy for SARS-CoV-2 to measure the degree of ventilation in a space. 90-94 In other words, testing of ventilation methods with active virus was not conducted.
- Theoretically, many factors influence whether ventilation is successful in the elimination or decrease of SARS-CoV-2 particles in the air, including
 - Activities taking place in the space,
 - Number of infectious people in a space and their viral load,
 - Air change rate, natural vs. mechanical ventilation, presence of air filtration. ⁹⁵
- Air purification or ventilation alone is not enough to decrease virus particles to below guideline levels, but ventilation, purification, and implementation of other mitigation measures (mask wearing, occupancy restrictions, surface cleaning) can reduce risk of infection drastically. 96-98
- Researchers created an app to determine exposure times and occupancy levels based on ventilation, room specifications, and other parameters.
- A 'state of the literature' review published in April 2021 determined that the quality of evidence was low, in terms of understanding the role of ventilation systems in mitigating or promoting spread of COVID-19.¹⁰⁰









Air Purification

- A study using surrogate viruses to test the effectiveness of air purification devices found that a HEPA H14 filter eliminated 99% of bacteriophages under perfect conditions.¹⁰¹
- Similarly, another study found that aerosol concentration decreased 90% after 30 minutes of running four air purifiers in a classroom with windows and doors closed.¹⁰²
- Additionally, the optimal positioning of air purifiers was in front of the source of aerosols (e.g., an infectious person), on the ground.¹⁰³
- Another study showed higher viral load concentrations when the air purifier was placed farther away from the particle emitter (range: 1.2m – 8.4m).¹⁰⁴









HVAC Systems

- There is a risk that HVAC systems could worsen spread of COVID-19 if not designed or modified to maximize circulation of virus-free air into a space. 103,105
- Displacement ventilation systems, or those "designed to vertically stratify indoor air by temperature (warm air at the top of the room, colder air at the bottom) and remove warmer air" were found most likely to reduce risk of SARS-CoV-2 transmission via HVAC. 105
- Conversely, another study found that unstable or neutrally stratified air (warm air at the bottom of the room, or no discriminate layers of warm or cold air) reduced the risk of infectious aerosols remaining at one height in the breathing environment.84
- Increasing the fraction of outdoor air and using a MERV-13 filter (rather than a MERV-8 filter) were found to be more likely to reduce spread of SARS-CoV-2 between adjoining rooms. 106
- Ventilation at only one point in a room is unlikely to efficiently remove virus particles in the absence of other precautions (masks, social distancing, etc.). 107
- Inadequate or inappropriately positioned ventilation may lead to virus hotspots or increased surface deposition. 105,107









Historic Buildings & Natural Ventilation

- In a school system in Switzerland, natural ventilation was performed during breaks and decreased the amount of carbon dioxide from 1600ppm to 1097ppm.⁹¹
- In a study of New York City school buildings, transmission was found to be lower in older buildings compared to newer buildings, likely due to "greater outdoor airflow" (i.e., drafts).
 - Transmission rate was also found to be lower in schools with mechanical ventilation (when compared to natural ventilation).¹⁰⁸
- A study of a historic building in Jeddah (Saudi Arabia) found that the number of windows opened (large windows with cross ventilation) was positively correlated with ventilation rates, while wind speed and direction were not.¹⁰⁹
- Conversely, it was found that atypically low wind speed and wind direction in a naturally ventilated building may have contributed to a COVID-19 outbreak in Hong Kong.⁹⁰









Effects of Temperature & Humidity

- Because ventilation with outdoor air is more difficult in colder months, researchers have estimated that airborne infection risk is double that of summer months.^{93,108,110}
 - During these months, monitoring indoor carbon dioxide as a proxy for ventilation is recommended and should not exceed 1000 ppm.¹¹⁰
 - In the absence of carbon dioxide monitoring, attention should be paid to areas where stagnant air is more likely.¹¹⁰
- Researchers in another study recommended further research on humidification of air, which could increase the speed at which SARS-CoV-2 particles drop to the ground or surfaces.¹¹¹









What is Still Unknown About the Impact of Ventilation on SARS-CoV-2?

- Consensus on how to best configure, upgrade, or design ventilation systems to mitigate the spread of SARS-CoV-2.
- How proximity to air purifiers (close to emitter vs. far away) impact the amount of virus particles present in a space.
- Whether variants that are more transmissible can be mitigated using the same ventilation methods that are effective for other strains.
- How results may differ if ventilation-related studies used SARS-CoV-2 instead of surrogate substances (e.g., carbon dioxide).









Key CDC Resources About Ventilation to Mitigate SARS-CoV-2

- Ventilation in Buildings
- COVID-19 Employer Information for Office Buildings
- Improving Ventilation in Your Home
- <u>Ventilation and Coronavirus (COVID-19)</u> (Environmental Protection Agency resource)









HOW THIS BRIEFING WAS CREATED (METHODOLOGY)









How This Briefing Was Created

- In January 2021, REALM stakeholders developed Phase 3 research questions. An additional question related to ventilation was added in May 2021.
- Battelle developed search strings that included variations of the term "SARS-CoV-2" and novel terms for vaccine and variants using Boolean operators. The Boolean operator "AND" was used to separate SARS-CoV-2 and research question terms, while different variations of the virus name and keywords related to the research question were grouped by category using parentheses and the Boolean operator "OR" (e.g., ["SARS-CoV-2" OR "2019-nCoV" OR "COVID-19"] AND [vaccine OR variant]). Search strings are included in the appendix.
- Battelle developed research question keywords using ad hoc test searches and comparison against known relevant articles, and databases were selected (Scopus, SciTech, Web of Science, and MEDLINE) to provide comprehensive search capacity and inclusion of smaller databases.
- The initial search string included a time criterion to capture articles published in January 2021 and after. Subsequent searches were executed on two-week durations. Note: when the ventilation research question was added in May 2021, articles were searched from January 1 forward to cover the same time period as the other research questions.









How This Briefing Was Created (cont.)

- Battelle staff reviewed the titles and abstracts of search results to select those most relevant to the research questions for additional examination.
- Selected popular press publications and the DHS <u>Master Question List for COVID-19</u> were reviewed to verify the completeness of the search results (i.e., to double-check that relevant articles were not missed by the searches).
- Battelle staff analyzed the relevant articles to identify key subtopics. Summaries of the articles, organized by subtopic, were presented to OCLC, IMLS, and REALM working groups for feedback.
- Battelle summarized the results for an initial briefing that was published on 15 April 2021, which summarized findings from articles published 01 January to 15 March 2021. The current briefing is a cumulative report that builds on the initial briefing by adding new relevant research findings published 16 March to 26 April 2021. Additional information was also added from the CDC to provide context on the key topics.
- Battelle will continue to review articles gathered by the search on a biweekly basis, and this briefing will continue to be updated iteratively with new and updated information.









REFERENCES CITED IN THIS BRIEFING









References

- 1. Centers for Disease Control and Prevention (CDC). COVID Data Tracker [Internet]. U.S.: CDC; 2021Apr13 [cited 2021Apr14]. Available from: https://covid.cdc.gov/covid-data-tracker/#datatracker-home
- 2. Department of Homeland Security (DHS) Science and Technology Directorate. Master question list for COVID-19 (caused by SARS-CoV-2). U.S.: DHS; 2021Mar25 [cited 2021Apr14]. Available from: https://www.dhs.gov/sites/default/files/publications/mgl_sars-cov-2_-cleared-for-public-release_2020_03_25.pdf
- 3. Centers for Disease Control and Prevention (CDC). Pfizer-BioNTech COVID-19 Vaccine Overview & Safety [Internet]. U.S.: CDC; 2021Apr5 [cited 2021Apr14]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/vaccines/different-vaccines/Pfizer-BioNTech.html
- 4. Centers for Disease Control and Prevention (CDC). Moderna COVID-19 Vaccine Overview & Safety [Internet]. U.S.: CDC; 2021Apr5 [cited 2021Apr14]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/vaccines/different-vaccines/Moderna.html
- 5. Centers for Disease Control and Prevention (CDC). Johnson & Johnson's Janssen COVID-19 Vaccine Overview & Safety [Internet. U.S.: CDC; 2021Apr13 [cited 2021Apr14]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/vaccines/janssen.html
- 6. Centers for Disease Control and Prevention (CDC). CDC Recommends Use of Johnson & Johnson's Janssen COVID-19 Vaccine Resume [Internet]. U.S.: CDC; 2021May06 [cited 2021May12]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/vaccines/safety/JJUpdate.html
- 7. Centers for Disease Control and Prevention (CDC). Key Things to Know about COVID-19 Vaccines[Internet]. U.S.: CDC;2021May12 [cited 2021May12]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/vaccines/keythingstoknow.html
- 8. Centers for Disease Control and Prevention (CDC). When You've Been Fully Vaccinated[Internet]. U.S.: CDC;2021May16 [cited 2021May16]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/vaccines/fully-vaccinated.html









- 9. Centers for Disease Control and Prevention (CDC). About variants of the virus that causes COVID-19 [Internet]. U.S.: CDC; 2021Mar17 [cited 2021Apr14]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/transmission/variant.html
- 10. Centers for Disease Control and Prevention (CDC). SARS-CoV-2 Variant Classifications and Definitions [Internet]. U.S.: CDC; 2021Mar24 [cited 2021Apr14]. Available from: https://www.cdc.gov/coronavirus/2019-ncov/cases-updates/variant-surveillance/variant-info.html
- 11. Centers for Disease Control and Prevention (CDC). Genomic Surveillance for SARS-CoV-2 Variants [Internet]. U.S.: CDC; 2021Apr3 [cited 2021Apr14]. https://www.cdc.gov/coronavirus/2019-ncov/cases-updates/variant-surveillance.html
- 12. Levine-Tiefenbrun M, Yelin I, Katz R, Herzel E, Golan Z, Schreiber L, et al. Initial report of decreased SARS-CoV-2 viral load after inoculation with the BNT162b2 vaccine. Nature medicine. 2021.
- 13. Jones NK, Rivett L, Seaman S, Samworth RJ, Warne B, Workman C, et al. Single-dose BNT162b2 vaccine protects against asymptomatic SARS-CoV-2 infection. eLife. 2021;10.
- 14. Keehner J, Horton LE, Pfeffer MA, Longhurst CA, Schooley RT, Currier JS, et al. SARS-CoV-2 Infection after Vaccination in Health Care Workers in California. The New England journal of medicine. 2021.
- 15. Widge AT, Rouphael NG, Jackson LA, Anderson EJ, Roberts PC, Makhene M, et al. Durability of Responses after SARS-CoV-2 mRNA-1273 Vaccination. New England Journal of Medicine. 2020;384(1):80-2.









- 16. Ebinger JE, Fert-Bober J, Printsev I, Wu M, Sun N, Figueiredo JC, et al. Prior COVID-19 Infection and Antibody Response to Single Versus Double Dose mRNA SARS-CoV-2 Vaccination. medRxiv. 2021.
- 17. Moghadas SM, Vilches TN, Zhang K, Wells CR, Shoukat A, Singer BH, et al. The impact of vaccination on COVID-19 outbreaks in the United States. Clinical infectious diseases: an official publication of the Infectious Diseases Society of America. 2021.
- 18. Baden LR, El Sahly HM, Essink B, Kotloff K, Frey S, Novak R, et al. Efficacy and Safety of the mRNA-1273 SARS-CoV-2 Vaccine. New England Journal of Medicine. 2020;384(5):403-16.
- 19. Gee J, Marquez P, Su J, Calvert GM, Liu R, Myers T, et al. First Month of COVID-19 Vaccine Safety Monitoring United States, December 14, 2020-January 13, 2021. MMWR Morbidity and mortality weekly report. 2021;70(8):283-8.
- 20. Lombardi A, Bozzi G, Ungaro R, Villa S, Castelli V, Mangioni D, et al. Mini Review Immunological Consequences of Immunization With COVID-19 mRNA Vaccines: Preliminary Results. Frontiers in immunology. 2021;12:657711.
- 21. Dyer O. Covid-19: Moderna and Pfizer vaccines prevent infections as well as symptoms, CDC study finds. BMJ (Clinical research ed). 2021;373:n888.
- 22. Sadoff J, Gray G, Vandebosch A, Cárdenas V, Shukarev G, Grinsztejn B, et al. Safety and Efficacy of Single-Dose Ad26.COV2.S Vaccine against Covid-19. The New England journal of medicine. 2021.
- 23. Sadoff J, Davis K, Douoguih M. Thrombotic Thrombocytopenia after Ad26.COV2.S Vaccination Response from the Manufacturer. The New England journal of medicine. 2021.
- 24. Nguyen KH, Srivastav A, Razzaghi H, Williams W, Lindley MC, Jorgensen C, et al. COVID-19 Vaccination Intent, Perceptions, and Reasons for Not Vaccinating Among Groups Prioritized for Early Vaccination United States, September and December 2020. MMWR Morbidity and mortality weekly report. 2021;70(6):217-22.









- 25. Webb Hooper M, Nápoles AM, Pérez-Stable EJ. No Populations Left Behind: Vaccine Hesitancy and Equitable Diffusion of Effective COVID-19 Vaccines. Journal of general internal medicine. 2021:1-4.
- 26. Guidry JPD, Laestadius LI, Vraga EK, Miller CA, Perrin PB, Burton CW, et al. Willingness to get the COVID-19 vaccine with and without emergency use authorization. American journal of infection control. 2021;49(2):137-42.
- 27. Khubchandani J, Sharma S, Price JH, Wiblishauser MJ, Sharma M, Webb FJ. COVID-19 Vaccination Hesitancy in the United States: A Rapid National Assessment. Journal of community health. 2021:1-8.
- 28. Ruiz JB, Bell RA. Predictors of intention to vaccinate against COVID-19: Results of a nationwide survey. Vaccine. 2021;39(7):1080-6.
- 29. Unroe KT, Evans R, Weaver L, Rusyniak D, Blackburn J. Willingness of Long-Term Care Staff to Receive a COVID-19 Vaccine: A Single State Survey. Journal of the American Geriatrics Society. 2020.
- 30. Lin C, Tu P, Beitsch LM. Confidence and Receptivity for COVID-19 Vaccines: A Rapid Systematic Review. Vaccines. 2020;9(1).
- 31. Kuppalli K, Brett-Major DM, Smith TC. COVID-19 Vaccine Acceptance: We Need to Start Now. Open Forum Infectious Diseases. 2021;8(2).
- 32. Schrading WA, Trent SA, Paxton JH, Rodriguez RM, Swanson MB, Mohr NM, et al. Vaccination Rates and Acceptance of SARS-CoV-2 Vaccination Among US Emergency Department Health Care Personnel. Academic emergency medicine: official journal of the Society for Academic Emergency Medicine. 2021.
- 33. Dodd RH, Pickles K, Nickel B, Cvejic E, Ayre J, Batcup C, et al. Concerns and motivations about COVID-19 vaccination. The Lancet Infectious diseases. 2021;21(2):161-3.









- 34. Momplaisir F, Haynes N, Nkwihoreze H, Nelson M, Werner RM, Jemmott J. Understanding Drivers of COVID-19 Vaccine Hesitancy Among Blacks. Clinical Infectious Diseases. 2021.
- 35. Food and Drug Administration (FDA). FDA and CDC Lift Recommended Pause on Johnson & Johnson (Janssen) COVID-19 Vaccine Use Following Thorough Safety Review. U.S.: FDA; 2021Apr23 [cited 2021May12]. Available from: https://www.fda.gov/news-events/press-announcements/fda-and-cdc-lift-recommended-pause-johnson-johnson-janssen-covid-19-vaccine-use-following-thorough
- 36. Shimabukuro TT, Kim SY, Myers TR, Moro PL, Oduyebo T, Panagiotakopoulos L, et al. Preliminary Findings of mRNA Covid-19 Vaccine Safety in Pregnant Persons. The New England journal of medicine. 2021.
- 37. Lin C, Tu P, Beitsch LM. Confidence and Receptivity for COVID-19 Vaccines: A Rapid Systematic Review. Vaccines. 2020;9(1).
- 38. Rzymski P, Borkowski L, Drąg M, Flisiak R, Jemielity J, Krajewski J, et al. The Strategies to Support the COVID-19 Vaccination with Evidence-Based Communication and Tackling Misinformation. Vaccines. 2021;9(2).
- 39. Loomba S, de Figueiredo A, Piatek SJ, de Graaf K, Larson HJ. Measuring the impact of COVID-19 vaccine misinformation on vaccination intent in the UK and USA. Nature Human Behaviour. 2021.
- 40. Marco-Franco JE, Pita-Barros P, Vivas-Orts D, González-de-Julián S, Vivas-Consuelo D. COVID-19, Fake News, and Vaccines: Should Regulation Be Implemented? International journal of environmental research and public health. 2021;18(2):744.
- 41. Sauer MA, Truelove S, Gerste AK, Limaye RJ. A Failure to Communicate? How Public Messaging Has Strained the COVID-19 Response in the United States. Health security. 2021;19(1):65-74.
- 42. Benham JL, Lang R, Kovacs Burns K, MacKean G, Léveillé T, McCormack B, et al. Attitudes, current behaviours and barriers to public health measures that reduce COVID-19 transmission: A qualitative study to inform public health messaging. PloS one. 2021;16(2):e0246941-e.





- 43. Laurencin CT. Addressing Justified Vaccine Hesitancy in the Black Community. Journal of racial and ethnic health disparities. 2021:1-4.
- 44. Reverby SM. Racism, disease, and vaccine refusal: People of color are dying for access to COVID-19 vaccines. PLoS biology. 2021;19(3):e3001167.
- 45. The National Academies of Sciences, Engineering, and Medicine. To Increase Confidence in COVID-19 Vaccines, Decision-Makers Need to Showcase Public Support, Leverage Endorsements, Focus on Hesitant Individuals, and Engage Communities. U.S.: The National Academies of Sciences, Engineering, and Medicine 2021Feb3 [cited 2021May12]. Available from: <a href="https://www.nationalacademies.org/news/2021/02/to-increase-confidence-in-covid-19-vaccines-decision-makers-need-to-showcase-public-support-leverage-endorsements-focus-on-hesitant-individuals-and-engage-communities
- 46. Eurosurveillance Editorial Team. Updated rapid risk assessment from ECDC on the risk related to the spread of new SARS-CoV-2 variants of concern in the EU/EEA first update. Euro surveillance: bulletin Europeen sur les maladies transmissibles = European communicable disease bulletin. 2021;26(3).
- 47. Galloway SE, Paul P, MacCannell DR, Johansson MA, Brooks JT, MacNeil A, et al. Emergence of SARS-CoV-2 B.1.1.7 Lineage United States, December 29, 2020-January 12, 2021. MMWR Morbidity and mortality weekly report. 2021;70(3):95-9.
- 48. Leung K, Shum MH, Leung GM, Lam TT, Wu JT. Early transmissibility assessment of the N501Y mutant strains of SARS-CoV-2 in the United Kingdom, October to November 2020. Euro surveillance: bulletin Europeen sur les maladies transmissibles = European communicable disease bulletin. 2021;26(1).
- 49. Wang P, Liu L, Iketani S, Luo Y, Guo Y, Wang M, et al. Increased Resistance of SARS-CoV-2 Variants B.1.351 and B.1.1.7 to Antibody Neutralization. Research square. 2021.









- 50. Washington NL, Gangavarapu K, Zeller M, Bolze A, Cirulli ET, Schiabor Barrett KM, et al. Genomic epidemiology identifies emergence and rapid transmission of SARS-CoV-2 B.1.1.7 in the United States. medRxiv. 2021.
- 51. Graham MS, Sudre CH, May A, Antonelli M, Murray B, Varsavsky T, et al. Changes in symptomatology, reinfection, and transmissibility associated with the SARS-CoV-2 variant B.1.1.7: an ecological study. The Lancet Public health. 2021;6(5):e335-e45.
- 52. Volz E, Mishra S, Chand M, Barrett JC, Johnson R, Geidelberg L, et al. Assessing transmissibility of SARS-CoV-2 lineage B.1.1.7 in England. Nature. 2021.
- 53. Washington NL, Gangavarapu K, Zeller M, Bolze A, Cirulli ET, Schiabor Barrett KM, et al. Emergence and rapid transmission of SARS-CoV-2 B.1.1.7 in the United States. Cell. 2021;184(10):2587-94.e7.
- 54. Davies NG, Abbott S, Barnard RC, Jarvis CI, Kucharski AJ, Munday JD, et al. Estimated transmissibility and impact of SARS-CoV-2 lineage B. 1.1. 7 in England. Science. 2021.
- 55. Haim-Boukobza S, Roquebert B, Trombert-Paolantoni S, Lecorche E, Verdurme L, Foulongne V, et al. Detecting Rapid Spread of SARS-CoV-2 Variants, France, January 26-February 16, 2021. Emerg Infect Dis. 2021;27(5).
- 56. Hu J, Peng P, Wang K, Liu B-z, Fang L, Luo F-y, et al. Emerging SARS-CoV-2 variants reduce neutralization sensitivity to convalescent sera and monoclonal antibodies. bioRxiv. 2021;2021.01.22.427749.
- 57. Wang R, Chen J, Gao K, Hozumi Y, Yin C, Wei GW. Analysis of SARS-CoV-2 mutations in the United States suggests presence of four substrains and novel variants. Communications biology. 2021;4(1):228.
- 58. Zhao S, Lou J, Cao L, Zheng H, Chong MKC, Chen Z, et al. Quantifying the transmission advantage associated with N501Y substitution of SARS-CoV-2 in the United Kingdom: An early data-driven analysis. Journal of travel medicine. 2021.









- 59. Zhao S, Lou J, Cao L, Zheng H, Chong MKC, Chen Z, et al. Modelling the association between COVID-19 transmissibility and D614G substitution in SARS-CoV-2 spike protein: using the surveillance data in California as an example. Theoretical biology & medical modelling. 2021;18(1):10.
- 60. Pereira F. SARS-CoV-2 variants combining spike mutations and the absence of ORF8 may be more transmissible and require close monitoring. Biochemical and biophysical research communications. 2021;550:8-14.
- 61. Kidd M, Richter A, Best A, Cumley N, Mirza J, Percival B, et al. S-variant SARS-CoV-2 lineage B1.1.7 is associated with significantly higher viral loads in samples tested by ThermoFisher TaqPath RT-qPCR. The Journal of Infectious Diseases. 2021.
- 62. Ives AR, Bozzuto C. Estimating and explaining the spread of COVID-19 at the county level in the USA. Communications biology. 2021;4(1):60.
- 63. Schuit M, Biryukov J, Beck K, Yolitz J, Bohannon J, Weaver W, et al. The stability of an isolate of the SARS-CoV-2 B.1.1.7 lineage in aerosols is similar to three earlier isolates. The Journal of infectious diseases. 2021.
- 64. Grint DJ, Wing K, Williamson E, McDonald HI, Bhaskaran K, Evans D, et al. Case fatality risk of the SARS-CoV-2 variant of concern B.1.1.7 in England, 16 November to 5 February. Euro surveillance: bulletin Europeen sur les maladies transmissibles = European communicable disease bulletin. 2021;26(11).
- 65. Davies NG, Jarvis CI, Edmunds WJ, Jewell NP, Diaz-Ordaz K, Keogh RH. Increased mortality in community-tested cases of SARS-CoV-2 lineage B.1.1.7. Nature. 2021.
- 66. Calistri P, Amato L, Puglia I, Cito F, Di Giuseppe A, Danzetta ML, et al. Infection sustained by lineage B.1.1.7 of SARS-CoV-2 is characterised by longer persistence and higher viral RNA loads in nasopharyngeal swabs. International journal of infectious diseases: IJID: official publication of the International Society for Infectious Diseases. 2021;105:753-5.









- 67. Nagy Á, Pongor S, Győrffy B. Different mutations in SARS-CoV-2 associate with severe and mild outcome. International journal of antimicrobial agents. 2021;57(2):106272.
- 68. Groves DC, Rowland-Jones SL, Angyal A. The D614G mutations in the SARS-CoV-2 spike protein: Implications for viral infectivity, disease severity and vaccine design. Biochemical and biophysical research communications. 2021;538:104-7.
- 69. Oulas A, Zanti M, Tomazou M, Zachariou M, Minadakis G, Bourdakou MM, et al. Generalized linear models provide a measure of virulence for specific mutations in SARS-CoV-2 strains. PloS one. 2021;16(1):e0238665.
- 70. Goyal M, De Bruyne K, van Belkum A, West B. Different SARS-CoV-2 haplotypes associate with geographic origin and case fatality rates of COVID-19 patients. Infection, genetics and evolution: journal of molecular epidemiology and evolutionary genetics in infectious diseases. 2021;90:104730.
- 71. Harrington D, Kele B, Pereira S, Couto-Parada X, Riddell A, Forbes S, et al. Confirmed Reinfection with SARS-CoV-2 Variant VOC-202012/01. Clinical infectious diseases: an official publication of the Infectious Diseases Society of America. 2021.
- 72. Zucman N, Uhel F, Descamps D, Roux D, Ricard JD. Severe reinfection with South African SARS-CoV-2 variant 501Y.V2: A case report. Clinical infectious diseases: an official publication of the Infectious Diseases Society of America. 2021.
- 73. Harrington D, Kele B, Pereira S, Couto-Parada X, Riddell A, Forbes S, et al. Confirmed Reinfection with SARS-CoV-2 Variant VOC-202012/01. Clinical infectious diseases: an official publication of the Infectious Diseases Society of America. 2021.
- 74. Leung K, Shum MH, Leung GM, Lam TT, Wu JT. Early transmissibility assessment of the N501Y mutant strains of SARS-CoV-2 in the United Kingdom, October to November 2020. Euro surveillance: bulletin Europeen sur les maladies transmissibles = European communicable disease bulletin. 2021;26(1).









- 75. Hu J, Peng P, Wang K, Liu B-z, Fang L, Luo F-y, et al. Emerging SARS-CoV-2 variants reduce neutralization sensitivity to convalescent sera and monoclonal antibodies. bioRxiv. 2021:2021.01.22.427749.
- 76. Reuschl AK, Thorne L, Zuliani Alvarez L, Bouhaddou M, Obernier K, Soucheray M, et al. Host-directed therapies against early-lineage SARS-CoV-2 retain efficacy against B.1.1.7 variant. bioRxiv. 2021.
- 77. Liu Y, Liu J, Xia H, Zhang X, Fontes-Garfias CR, Swanson KA, et al. Neutralizing Activity of BNT162b2-Elicited Serum. New England Journal of Medicine. 2021.
- 78. Zou J, Xie X, Fontes-Garfias CR, Swanson KA, Kanevsky I, Tompkins K, et al. The effect of SARS-CoV-2 D614G mutation on BNT162b2 vaccine-elicited neutralization. NPJ vaccines. 2021;6(1):44.
- 79. Wu K, Werner AP, Moliva JI, Koch M, Choi A, Stewart-Jones GBE, et al. mRNA-1273 vaccine induces neutralizing antibodies against spike mutants from global SARS-CoV-2 variants. bioRxiv. 2021:2021.01.25.427948.
- 80. Shen X, Tang H, Pajon R, Smith G, Glenn GM, Shi W, et al. Neutralization of SARS-CoV-2 Variants B.1.429 and B.1.351. The New England journal of medicine. 2021.
- 81. Edara VV, Hudson WH, Xie X, Ahmed R, Suthar MS. Neutralizing Antibodies Against SARS-CoV-2 Variants After Infection and Vaccination. JAMA. 2021.
- 82. Lustig Y, Nemet I, Kliker L, Zuckerman N, Yishai R, Alroy-Preis S, et al. Neutralizing Response against Variants after SARS-CoV-2 Infection and One Dose of BNT162b2. The New England journal of medicine. 2021.
- 83. Stamatatos L, Czartoski J, Wan YH, Homad LJ, Rubin V, Glantz H, et al. mRNA vaccination boosts cross-variant neutralizing antibodies elicited by SARS-CoV-2 infection. Science. 2021.









- 84. Galloway SE, Paul P, MacCannell DR, Johansson MA, Brooks JT, MacNeil A, et al. Emergence of SARS-CoV-2 B.1.1.7 Lineage United States, December 29, 2020-January 12, 2021. MMWR Morbidity and mortality weekly report. 2021;70(3):95-9.
- 85. Grubaugh ND, Hodcroft EB, Fauver JR, Phelan AL, Cevik M. Public health actions to control new SARS-CoV-2 variants. Cell. 2021;184(5):1127-32.
- 86. Moore JP, Offit PA. SARS-CoV-2 Vaccines and the Growing Threat of Viral Variants. JAMA. 2021;325(9):821-2.
- 87. Arruda EF, Pastore DH, Dias CM, Das SS. Modelling and Optimal Control of Multi Strain Epidemics, with Application to COVID-19. Ithaca: Cornell University Library, arXiv.org; 2021.
- 88. Di Domenico L, Sabbatini CE, Pullano G, Lévy-Bruhl D, Colizza V. Impact of January 2021 curfew measures on SARS-CoV-2 B.1.1.7 circulation in France. Euro surveillance: bulletin Europeen sur les maladies transmissibles = European communicable disease bulletin. 2021;26(15).
- 89. Borges V, Sousa C, Menezes L, Gonçalves AM, Picão M, Almeida JP, et al. Tracking SARS-CoV-2 lineage B.1.1.7 dissemination: insights from nationwide spike gene target failure (SGTF) and spike gene late detection (SGTL) data, Portugal, week 49 2020 to week 3 2021. Euro surveillance: bulletin Europeen sur les maladies transmissibles = European communicable disease bulletin. 2021;26(10).
- 90. Tung CW, Mak CM, Niu JL, Hung K, Wu Y, Tung N, Wong HM. Enlightenment of re-entry airflow: The path of the airflow and the airborne pollutants transmission in buildings. Building and Environment. 2021 May 15;195:107760.
- 91. Vassella CC, Koch J, Henzi A, Jordan A, Waeber R, Iannaccone R, Charrière R. From spontaneous to strategic natural window ventilation: Improving indoor air quality in Swiss schools. International Journal of Hygiene and Environmental Health. 2021 May 1;234:113746.









- 92. Burridge HC, Fan S, Jones RL, Noakes CJ, Linden PF. Predictive and retrospective modelling of airborne infection risk using monitored carbon dioxide. arXiv preprint arXiv:2009.02999. 2020 Sep 7.
- 93. Vouriot CV, Burridge HC, Noakes CJ, Linden PF. Seasonal variation in airborne infection risk in schools due to changes in ventilation inferred from monitored carbon dioxide. Indoor air. 2021 Mar 8.
- 94. Deng X, Gong G, He X, Shi X, Mo L. Control of exhaled SARS-CoV-2-laden aerosols in the interpersonal breathing microenvironment in a ventilated room with limited space air stability. Journal of Environmental Sciences. 2021 Oct 1;108:175-87.
- 95. Jones B, Sharpe P, Iddon C, Hathway EA, Noakes CJ, Fitzgerald S. Modelling uncertainty in the relative risk of exposure to the SARS-CoV-2 virus by airborne aerosol transmission in well mixed indoor air. Building and environment. 2021 Mar 15;191:107617.
- 96. Blocken B, van Druenen T, Ricci A, Kang L, van Hooff T, Qin P, Xia L, Ruiz CA, Arts JH, Diepens JF, Maas GA. Ventilation and air cleaning to limit aerosol particle concentrations in a gym during the COVID-19 pandemic. Building and Environment. 2021 Apr 15:193:107659.
- 97. D'Orazio M, Bernardini G, Quagliarini E. A probabilistic model to evaluate the effectiveness of main solutions to COVID-19 spreading in university buildings according to proximity and time-based consolidated criteria.
- 98. Kennedy, M.; Lee, S. J.; Epstein, M., Modeling aerosol transmission of SARS-CoV-2 in multi-room facility. Journal of Loss Prevention in the Process Industries 2020, 104336.
- 99. Bazant MZ, Bush JW. Beyond six feet: A guideline to limit indoor airborne transmission of covid-19. medRxiv. 2020 Jan 1.
- 100.Goodwin L, Hayward T, Krishan P, Nolan G, Nundy M, Ostrishko K, Attili A, Cárceles SB, Epelle EI, Gabl R, Pappa EJ. Which factors influence the extent of indoor transmission of SARS-CoV-2? A rapid evidence review. Journal of global health. 2021;11.









- 101. Zacharias N, Haag A, Brang-Lamprecht R, Gebel J, Essert SM, Kistemann T, Exner M, Mutters NT, Engelhart S. Air filtration as a tool for the reduction of viral aerosols. Science of The Total Environment. 2021 Jun 10;772:144956.
- 102. Curtius J, Granzin M, Schrod J. Testing mobile air purifiers in a school classroom: Reducing the airborne transmission risk for SARS-CoV-2. Aerosol Science and Technology. 2021 Mar 25;55(5):586-99.
- 103. Narayanan SR, Yang S. Airborne transmission of virus-laden aerosols inside a music classroom: Effects of portable purifiers and aerosol injection rates. Physics of Fluids. 2021 Mar 1;33(3):033307.
- 104. Burgmann S, Janoske U. Transmission and reduction of aerosols in classrooms using air purifier systems. Physics of Fluids. 2021 Mar 23;33(3):033321.
- 105. Farthing TS, Lanzas C. Assessing the efficacy of interventions to control indoor SARS-Cov-2 transmission: an agent-based modeling approach. medRxiv. 2021 Jan 1.
- 106. Pease LF, Wang N, Salsbury TI, Underhill RM, Flaherty JE, Vlachokostas A, Kulkarni G, James DP. Investigation of potential aerosol transmission and infectivity of SARS-CoV-2 through central ventilation systems. Building and Environment. 2021 Jan 29:107633.
- 107. Shao S, Zhou D, He R, Li J, Zou S, Mallery K, Kumar S, Yang S, Hong J. Risk assessment of airborne transmission of COVID-19 by asymptomatic individuals under different practical settings. Journal of aerosol science. 2021 Jan 1;151:105661.
- 108. Pavilonis B, Ierardi AM, Levine L, Mirer F, Kelvin EA. Estimating aerosol transmission risk of SARS-CoV-2 in New York City public schools during reopening. Environmental Research. 2021 Apr 1;195:110805.









- 109. Alaidroos, A., Almaimani, A., Baik, A., Al-Amodi, M. and Rahaman, K.R., 2021. Are Historical Buildings More Adaptive to Minimize the Risks of Airborne Transmission of Viruses and Public Health? A Study of the Hazzazi House in Jeddah (Saudi Arabia). International Journal of Environmental Research and Public Health, 18(7), p.3601.
- 110. Burridge HC, Bhagat RK, Stettler ME, Kumar P, De Mel I, Demis P, Hart A, Johnson-Llambias Y, King MF, Klymenko O, McMillan A. The ventilation of buildings and other mitigating measures for COVID-19: a focus on wintertime. Proceedings of the Royal Society A. 2021 Mar 31;477(2247):20200855..
- 111. Arias FJ, De Las Heras S. The mechanical effect of moisturization on airborne COVID-19 transmission and its potential use as control technique. Environmental research. 2021 Jun 1;197:110940.









APPENDIX: SEARCH STRINGS









| Database | Strategy: Vaccines and Variants of SARS-CoV-2 |
|----------------|---|
| Scopus | ((TITLE-ABS (coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND TITLE-ABS (spread* OR transmi* OR infect* OR reinfect* OR virulence OR neutraliz* OR sever* OR evad* OR airborne OR aerosol* OR occupation* OR infectiv* OR mortality OR morbidity OR death*) AND TITLE-ABS (variant OR vaccine OR mutat* OR mutant* OR lineage OR immun* OR strain)) AND NOT TITLE-ABS (receptor OR inflamm* OR peptide* OR nanomaterial OR ace2 OR polymerase OR "IgA" OR patient* OR assay* OR ligand* OR protease OR hiv)) |
| SciTech | (ti,ab(coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND ti,ab(spread* OR transmi* OR infect* OR reinfect* OR virulence OR neutraliz* OR sever* OR evad* OR airborne OR aerosol* OR occupation* OR infectiv* OR mortality OR morbidity OR death*) AND ti,ab(variant OR vaccine OR mutat* OR mutant* OR lineage OR immun* OR strain)) NOT ti,ab(receptor OR inflamm* OR peptide* OR nanomaterial OR ace2 OR polymerase OR "IgA" OR patient* OR assay* OR ligand* OR protease OR hiv) |
| Web of Science | TS=(coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND TS=(spread* OR transmi* OR infect* OR reinfect* OR virulence OR neutraliz* OR sever* OR evad* OR airborne OR aerosol* OR occupation* OR infectiv* OR mortality OR morbidity OR death*) AND TS=(variant OR vaccine OR mutat* OR mutant* OR lineage OR immun* OR strain) NOT TS=(receptor OR inflamm* OR peptide* OR nanomaterial OR ace2 OR polymerase OR "IgA" OR patient* OR assay* OR ligand* OR protease OR hiv) |
| MEDLINE | (TI (coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND TI (spread* OR transmi* OR infect* OR reinfect* OR virulence OR neutraliz* OR sever* OR evad* OR airborne OR aerosol* OR occupation* OR infectiv* OR mortality OR morbidity OR death*) AND TI (variant OR vaccine OR mutat* OR mutant* OR lineage OR immun* OR strain) NOT TI (receptor OR inflamm* OR peptide* OR nanomaterial OR ace2 OR polymerase OR "IgA" OR patient* OR assay* OR ligand* OR protease OR hiv)) OR (AB (coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND AB (spread* OR transmi* OR infect* OR reinfect* OR virulence OR neutraliz* OR sever* OR evad* OR airborne OR aerosol* OR occupation* OR infectiv* OR mortality OR morbidity OR death*) AND AB (variant OR vaccine OR mutat* OR lineage OR immun* OR strain) NOT AB (receptor OR inflamm* OR peptide* OR nanomaterial OR ace2 OR polymerase OR "IgA" OR patient* OR assay* OR ligand* OR protease OR hiv)) |









| Database | Strategy: Effects of Ventilation on Spread of SARS-CoV-2 |
|----------------|--|
| Scopus | (TITLE-ABS (coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND TITLE-ABS (spread* OR transmi* OR persist* OR mitigat* OR purif* OR reduc*) AND TITLE-ABS (indoor OR office OR "climate controlled" OR ambient OR air OR airborne OR aerosol* OR hvac OR merv OR filter* OR filtrat* OR ventilat* OR hepa)) AND NOT TITLE-ABS (pollution OR particulate* OR hospital* OR nosocomial OR animal OR wastewater OR sewage OR "intensive care" OR patient OR phenotype OR clinical OR polymerase) AND (LIMIT-TO (PUBYEAR, 2021)) |
| SciTech | (TS=(coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND TS=(spread* OR transmi* OR persist* OR mitigat* OR purif* OR reduc*) AND TS=(indoor OR office OR "climate controlled" OR ambient OR air OR airborne OR aerosol* OR hvac OR merv OR filter* OR filtrat* OR ventilat* OR hepa)) NOT TS=(pollution OR particulate* OR hospital* OR nosocomial OR animal OR wastewater OR sewage OR "intensive care" OR patient OR phenotype OR clinical OR polymerase) AND PUB YEAR= 2021 |
| Web of Science | (TI (coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") OR AB (coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV")) AND (TI (spread* OR transmi* OR persist* OR mitigat* OR purif* OR reduc*) OR AB (spread* OR transmi* OR persist* OR mitigat* OR purif* OR reduc*)) AND (TI (indoor OR office OR "climate controlled" OR ambient OR air OR airborne OR aerosol* OR hvac OR merv OR filter* OR filtrat* OR ventilat* OR hepa) OR AB (indoor OR office OR "climate controlled" OR ambient OR air OR airborne OR aerosol* OR hvac OR merv OR filter* OR filtrat* OR ventilat* OR hosocomial OR airborne OR aerosol* OR hvac OR merv OR filter* OR filtrat* OR ventilat* OR hosocomial OR animal OR wastewater OR sewage OR "intensive care" OR patient OR phenotype OR clinical OR polymerase) OR AB (pollution OR particulate* OR hospital* OR nosocomial OR animal OR wastewater OR sewage OR "intensive care" OR patient OR phenotype OR clinical OR polymerase)) Date of Publication: 20210101-20211231 |
| MEDLINE | (ti,ab(coronavir* OR covid OR "COVID-19" OR "SARS-CoV-2" OR "2019-nCoV") AND ti,ab(spread* OR transmi* OR persist* OR mitigat* OR purif* OR reduc*) AND ti,ab(indoor OR office OR "climate controlled" OR ambient OR air OR airborne OR aerosol* OR hvac OR merv OR filter* OR filtrat* OR ventilat* OR hepa)) NOT ti,ab(pollution OR particulate* OR hospital* OR nosocomial OR animal OR wastewater OR sewage OR "intensive care" OR patient OR phenotype OR clinical OR polymerase) Date: After January 01 2021 |









REALM PROJECT

REopening Archives, Libraries, and Museums

oc.lc/realm-project

#REALMproject

